

**Office of the
Executive Engineer, Electrical Inspectorate, Haryana,
526/19, Shivaji Nagar, Opp. S.D Public School (Khandsa Road),
Gurugram (e-mail: xenceiggn@gmail.com).**

To

M/s Eltex India Pvt. Ltd.
C/o Rajesh Kumar Saroj
Plot No. 13, Sector-08,
IMT Manesar, Gurugram.

Application No. 3875-5212

Dated: 02/02/2022

Memo No: H.T.I / 3457

Dated: 21/02/2022


Subject: Annual inspection of installation comprising of 1x800 KVA T/F & 1x250 KVA D.G Set under Rule Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010 for the year 2022 (from January 2022 to December 2022).

The subject cited installation was inspected by this department on 18.02.2022 and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2010. The following observations to be attended under intimation to this office:-

1. LT breaker be installed near the T/F.
2. Oil leakage from T/F be set right.

Consistent compliance of the relevant provisions of CEA Regulations, 2010 be ensured in the installation at your end and the electrical installation be maintain and operated in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

You are further advised to install the smart meter to read the energy generated and send the monthly statement of the units generated from your DG Sets to this department.


Executive Engineer
Electrical Inspectorate, Haryana,
1st Floor, 526/19, Shivaji Nagar,
Gurugram.
Opp. S.D Public School, Gurugram-I